

Date Issued	March 12, 2025	Status	Closed
Provider Name	USD VUCUREVICH CHILDRENS CENTER		
Provider ID	000097127		
Provider Address	Vucurevich Children's Center, 224 SD-50, Vermillion, SD 57069, USA		
Provider Contact	Dawna Andersen		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

The exterior exit from screened in porch was blocked with snow.

Corrections to be Made:

Exits needs to remain unblocked at all times

Corrections Made:

Snow has been removed from the area

Anticipated Completion Date:

March 31, 2025

Date Completed:

March 12, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Dawna Andersen

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

March 12, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Rita Trager

Printed Name of DSS Staff



3/12/2025, 1:46:22 PM

Signature of DSS Staff:

March 12, 2025

Date