

Date Issued	March 17, 2025	Status	Closed
Provider Name	<u>SCHOOL OF EARLY EDUCATION -BRANDON</u>		
Provider ID	<u>018043091</u>		
Provider Address	<u>701 8th Ave, Brandon, SD 57005, USA</u>		
Provider Contact	<u>Chelsea DeJonge</u>		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

The program did not have a carbon monoxide detector installed.

Corrections to be Made:

A carbon monoxide detector must be installed according to the manufacturer's instructions.

Corrections Made:

The program installed a carbon monoxide detector.

Anticipated Completion Date:
March 28, 2025

Date Completed:
March 17, 2025

Compliance Plan Action #2

Administrative Rule:

67:42:17:39

For family day care providers, unused electrical outlets must have an outlet plug cover, have a tamper-resistant cover, or be made inaccessible to a child. For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

Summary of Non-Compliance Finding:

There was an outlet not secured to the wall.

Corrections to be Made:

For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

Corrections Made:

The outlet was secured to the wall immediately.

Anticipated Completion Date:

March 17, 2025

Date Completed:

March 17, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Heather Groos

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

March 17, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Brooke Flemmer

Printed Name of DSS Staff



Signature of DSS Staff:

March 17, 2025

Date

3/17/2025, 11:17:09 AM