

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

The program did not have a carbon monoxide detector installed.

Corrections to be Made:

A carbon monoxide detector must be installed according to the manufacturer's instructions.

Corrections Made:

The program installed a carbon monoxide detector.

Anticipated Completion Date:

March 28, 2025

Date Completed:

March 26, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Wendy Jessip

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

March 18, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Brooke Flemmer

Printed Name of DSS Staff



3/17/2025, 11:08:53 AM

Signature of DSS Staff:

March 17, 2025

Date