

Date Issued	March 27, 2025	Status	Closed
Provider Name	LITTLE TIKES DAYCARE		
Provider ID	014512098		
Provider Address	512 Main St, Alexandria, SD 57311, USA		
Provider Contact	Tori Tegethoff		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

The east exit storm door on the main level of building was locked during daycare hours.

The school auditorium is used for large motor play and the SW exit of the building was obstructed by a rack of chairs.

Corrections to be Made:

All building exits must remain unlocked during daycare hours and exits must remain clear of obstructions at all times.

Corrections Made:

All providers were advised that exits must remain unlocked and unblocked at all times. The school was consulted on the auditorium exits and they advised that providers can move items as needed to assure exits are unblocked.

Anticipated Completion Date:

Date Completed:

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Tori Tegethoff

Printed Name of Provider/Agency Contact

Signature of Provider/Agency Contact

March 27, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Deb Bigge

Printed Name of DSS Staff



Signature of DSS Staff:

March 26, 2025

Date

3/26/2025, 2:15:28 PM