

| | | | |
|------------------|--|--------|--------|
| Date Issued | April 01, 2025 | Status | Closed |
| Provider Name | <u>CANDYLAND CHILD DEVELOPMENT CENTER</u> | | |
| Provider ID | <u>016597844</u> | | |
| Provider Address | <u>471 Constitution Blvd, Box Elder, SD 57719, USA</u> | | |
| Provider Contact | <u>Sandy Christman</u> | | |

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

A blanket was observed covering an exit door.

Two classrooms exit doors are sealed closed with silicone.

Corrections to be Made:

Program will need to remove the blanket from the exit door in the classroom and submit verification to the Office of Licensing & Accreditation.

Program will need to remove the silicone from the exit doors in the two classrooms and submit verification to the Office of Licensing & Accreditation.. Doors must be easily openable in the event of an emergency.

Corrections Made:

The blanket has been removed from the exit door and photo verification provided to the Office of Licensing & Accreditation on 3/21/2025.

The silicone has been removed from the exit doors in the two classrooms and verification submitted to the Office of Licensing & Accreditation on 3/21/2025.

Anticipated Completion Date:
April 01, 2025

Date Completed:
April 01, 2025

Compliance Plan Action #2

Administrative Rule:

67:42:17:33

A provider shall meet the following requirements regarding bathrooms:

- (1) Bathroom facilities must be easily accessible by children and providers;
- (2) Hot water for faucets normally used by children in care may not exceed one hundred twenty degrees Fahrenheit;
- (3) Toilets and hand sinks must be kept clean and in good repair; and
- (4) For child care centers and school-age programs:
 - (4a) All bathrooms must have natural or mechanical ventilation;
 - (4b) Separate bathrooms must be available for males and females;
 - (4c) Ratios for toilet and hand sinks must align with the minimum standards for plumbing and plumbing systems published by the plumbing commission.

Except in a family day care, hand sinks must be in the same room, or an unobstructed room adjacent to the diaper changing area. A handwashing sink used after diapering and toileting may not be used for food preparation.

Summary of Non-Compliance Finding:

An handwashing sink in a classroom is being used to prepare bottles.

Corrections to be Made:

Handwashing sinks cannot be used to prepare bottles. Water for bottles should be provided from the kitchen sink or bottled water. The program will submit a plan of action to the Office of Licensing & Accreditation.

Corrections Made:

Program submitted a plan of action to the Office of Licensing & Accreditation on 3/21/2025 stating water for bottles will be provided from the kitchen sink in a pitcher.

Anticipated Completion Date:
April 01, 2025

Date Completed:
April 01, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Sandy Christman

Printed Name of Provider/Agency Contact

Sandy Christman

Signature of Provider/Agency Contact

March 21, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Andrea Neff

Printed Name of DSS Staff



3/19/2025, 9:14:10 AM

Signature of DSS Staff:

March 19, 2025

Date