

Date Issued	April 07, 2025	Status	Closed
Provider Name	KID'S WORLD LEARNING CENTER		
Provider ID	011512327		
Provider Address	2220 6th St, Brookings, SD 57006, USA		
Provider Contact	Robin Rice		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:39

For family day care providers, unused electrical outlets must have an outlet plug cover, have a tamper-resistant cover, or be made inaccessible to a child. For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

Summary of Non-Compliance Finding:

At time of inspection, some of the outlet covers were damaged and need replaced.

Corrections to be Made:

For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

Corrections Made:

Verification received that all outlets have been updated with self-closing outlet cover or tamper-resistant cover.

Anticipated Completion Date:

April 15, 2025

Date Completed:

April 07, 2025

Compliance Plan Action #2

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable

window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and

(5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

At time of inspection, a carbon monoxide detector was not installed according to manufacturer's instructions.

Corrections to be Made:

A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the facility.

Corrections Made:

Verification received that carbon monoxide detector is installed according to manufacturer's instructions.

Anticipated Completion Date:

April 15, 2025

Date Completed:

April 07, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Robin Rice

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

April 07, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Ambuer Jaacks

Printed Name of DSS Staff



4/7/2025, 1:39:00 PM

Signature of DSS Staff:

April 07, 2025

Date