

Date Issued April 09, 2025 Status Closed

Provider Name CUSTER YMCA CHILD DEVELOPMENT CENTER

Provider ID 016598760

Provider Address 1315 Bluebell Ln, Custer, SD 57730, USA

Provider Contact Kandra Posey

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

Exit signs were not operational in the baby room and 3 year old room. Exit signs must be operational at all times.

Corrections to be Made:

Exit signs must be remain operational and illuminated. Verification the exit light are working must be sent to OLA.

Corrections Made:

The program submitted a signed statement stating that the exit lights had been repaired and were operational.

Anticipated Completion Date:
April 14, 2025

Date Completed:
April 24, 2025

Compliance Plan Action #2

Administrative Rule:

67:42:17:31

An infant shall be fed according to the infant's schedule. The provider shall hold the infant's bottle when feeding the infant. The provider may not feed an infant by propping up the infant's bottle. Food, including breast milk and formula, must be properly stored, kept at the proper temperature, and protected from potential contamination according to the preparing, feeding, and storing standards contained in Caring for Our Children: National Health and Safety Performance Standards, 4th Edition.

Summary of Non-Compliance Finding:

Fresh fruit was sitting on the floor.

Corrections to be Made:

Food must be stored correctly and removed from the floor.

Corrections Made:

The food was moved immediately. The inspector educated the program on proper storage of food.

Anticipated Completion Date:

April 14, 2025


Date Completed:

April 14, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Erin Wilkins

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

April 09, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Tina Uecker

Printed Name of DSS Staff



Signature of DSS Staff:

April 09, 2025

Date

4/9/2025, 10:24:33 AM