

**COMPLIANCE PLAN**  
**OFFICE OF LICENSING & ACCREDITATION**



|                  |                                     |        |        |
|------------------|-------------------------------------|--------|--------|
| Date Issued      | April 01, 2025                      | Status | Closed |
| Provider Name    | COUGAR KIDS                         |        |        |
| Provider ID      | 018040415                           |        |        |
| Provider Address | 501 Adams St, Hurley, SD 57036, USA |        |        |
| Provider Contact | Jill Dangel                         |        |        |

The items listed below are those that the provider was not in compliance with at the time of the inspection.

**Compliance Plan Action #1**

**Administrative Rule:**

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

**Summary of Non-Compliance Finding:**

Verification of a fire alarm system inspection completed in the past year was not available. A carbon monoxide detector is needed.

**Corrections to be Made:**

An inspection of the fire alarm system must be completed within the next month. A carbon monoxide detector must be installed.

**Corrections Made:**

Verification was received on 04/11/25 that a carbon monoxide detector was installed. Verification was received on 04/28/25 that an inspection of the fire alarm system had been completed within the past year.

**Anticipated Completion Date:**  
April 26, 2025

**Date Completed:**  
April 28, 2025

## Compliance Plan Action #2

### **Administrative Rule:**

67:42:17:44

All toxic or hazardous substances must be:

- (1) Inaccessible to children;
- (2) Used according to manufacturer's instructions;
- (3) Stored in the original or other labeled container; and
- (4) Disposed of according to manufacturer recommendations.

Bio-contaminants must be handled and disposed of properly. Soiled diapers must be changed promptly, in a designated area, on a non-porous surface. The diaper changing area must be clean and disinfected with a sanitizing solution approved by the department. Soiled diapers must be kept in a leakproof, nonabsorbent container that is covered with a tight-fitting lid.

### **Summary of Non-Compliance Finding:**

Chemicals stored under the bathroom sink are accessible to children.

### **Corrections to be Made:**

Chemicals must be moved to an inaccessible location or the cabinet must be locked to prevent access by children.

### **Corrections Made:**

Verification was received that the chemicals were moved to an inaccessible location on 03/6/25.

**Anticipated Completion Date:**

April 01, 2025


**Date Completed:**

April 01, 2025

**Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.**

Jill Dangel

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

April 01, 2025

Date

**The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.**

Deb Bigge

Printed Name of DSS Staff

*Deb Biggs*

3/28/2025, 8:54:13 AM

Signature of DSS Staff:

March 28, 2025

Date