

Date Issued April 09, 2025 Status Closed

Provider Name SHANTZ, SHARON

Provider ID 013002034

Provider Address 3013 Meadow Dr, Redfield, SD 57469, USA

Provider Contact SHARON SHANTZ

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:33

A provider shall meet the following requirements regarding bathrooms:

- (1) Bathroom facilities must be easily accessible by children and providers;
- (2) Hot water for faucets normally used by children in care may not exceed one hundred twenty degrees Fahrenheit;

- (3) Toilets and hand sinks must be kept clean and in good repair; and
- (4) For child care centers and school-age programs:
 - (4a) All bathrooms must have natural or mechanical ventilation;
 - (4b) Separate bathrooms must be available for males and females;
 - (4c) Ratios for toilet and hand sinks must align with the minimum standards for plumbing and plumbing systems published by the plumbing commission.

Except in a family day care, hand sinks must be in the same room, or an unobstructed room adjacent to the diaper changing area. A handwashing sink used after diapering and toileting may not be used for food preparation.

Summary of Non-Compliance Finding:

The hot water temperature is 128.8 degrees.

Corrections to be Made:

The hot water temperature needs to be 120 degrees or lower.

Corrections Made:


The Provider adjusted the hot water temperature to 120 degrees.

Anticipated Completion Date:
April 21, 2025

Date Completed:
April 09, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Sharon shantz
Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact


April 09, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Julie Hermansen

Printed Name of DSS Staff



4/8/2025, 1:12:37 PM

Signature of DSS Staff:

April 08, 2025

Date