

Date Issued	March 10, 2025	Status	Closed
Provider Name	YMCA CHILD CARE		
Provider ID	016523586		
Provider Address	815 Kansas City St, Rapid City, SD 57701, USA		
Provider Contact	Eve Finnegan		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:44

All toxic or hazardous substances must be:

- (1) Inaccessible to children;
- (2) Used according to manufacturer's instructions;
- (3) Stored in the original or other labeled container; and
- (4) Disposed of according to manufacturer recommendations.

Bio-contaminants must be handled and disposed of properly. Soiled diapers must be changed promptly, in a designated area, on a non-porous surface. The diaper changing area must be clean and disinfected with a sanitizing solution approved by the department. Soiled diapers must be kept in a leakproof, nonabsorbent container that is covered with a tight-fitting lid.

Summary of Non-Compliance Finding:

The diaper changing pad in the Little Rascals room is cracked, is not easily cleanable, and needs replaced. All diaper changing pads must be easily cleanable and non-absorbent.

Corrections to be Made:

The program must replace the diaper changing pad and verification must be sent to the Office of Licensing and Accreditation.

Corrections Made:

The program replaced the diaper changing pad and submitted receipts to OLA.

Anticipated Completion Date:
March 28, 2025

Date Completed:
April 30, 2025

Compliance Plan Action #2

Administrative Rule:

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean

and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

The maintenance door in the Happy Campers room needs a new door sweep and weather stripping. All doors must be in good repair.

Corrections to be Made:

The door sweep and weather stripping must be repaired and verification must be sent to the Office of Licensing and Accreditation.

Corrections Made:

The program repaired the weather stripping and sent receipts to OLA.

Anticipated Completion Date:

March 28, 2025


Date Completed:

April 30, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Eve Finnegan

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

March 04, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Tina Uecker

Printed Name of DSS Staff



Signature of DSS Staff:

May 01, 2025

Date

5/1/2025, 7:37:06 AM