

Summary of Non-Compliance Finding:

The outdoor play area is not fully enclosed; there is a 12-inch gap between the fence and the new storage structure that leads to the parking lot.

Corrections to be Made:

A fence at least four feet high is required around a center program's outdoor play space.

Corrections Made:

The provider submitted a photo verifying that a fence has been installed to enclose the twelve-inch gap.

Anticipated Completion Date:

June 06, 2025


Date Completed:

May 28, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Rayna Lowe

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact


May 06, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Teri Pieters

Printed Name of DSS Staff



Signature of DSS Staff:

May 28, 2025

Date