
Date Issued	May 28, 2025	Status	Closed
Provider Name	KIDSTOP - MEADOWBROOK		
Provider ID	016531018		
Provider Address	3125 W Flormann St, Rapid City, SD 57702, USA		
Provider Contact	Alisa Cunningham		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:39

For family day care providers, unused electrical outlets must have an outlet plug cover, have a tamper-resistant cover, or be made inaccessible to a child. For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

Summary of Non-Compliance Finding:

The electrical outlets are not tamper-resistant or have self-closing outlet covers.

Corrections to be Made:

Unused electrical outlets must have a self-closing outlet cover or tamper-resistant covers installed, and verification must be sent to OLA.

Corrections Made:

The program submitted verification on 5/23/2025 that tamper-resistant outlets have been installed.

Anticipated Completion Date:
May 30, 2025

Date Completed:
May 29, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Alisa Cunningham
Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

May 28, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Tina Uecker

Printed Name of DSS Staff



5/23/2025, 8:51:52 AM

Signature of DSS Staff:

May 23, 2025

Date
