

Date Issued	April 14, 2025	Status	Closed
Provider Name	DOLAND COMMUNITY DAYCARE		
Provider ID	011102464		
Provider Address	202 3rd St, Doland, SD 57436, USA		
Provider Contact	Melinda Rowe		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

### Compliance Plan Action #1

**Administrative Rule:**

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

**Summary of Non-Compliance Finding:**

The carbon monoxide detector is not properly functioning due to consistent beeping. The carbon monoxide detector needs to be replaced.

**Corrections to be Made:**

The daycare needs an operating carbon monoxide detector installed according to the manufacturer's directions.

**Corrections Made:**

An operating carbon monoxide detector was installed according to the manufacturer's directions.

**Anticipated Completion Date:**  
April 14, 2025

**Date Completed:**  
May 06, 2025

**Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.**

Melinda J Rowe

Printed Name of Provider/Agency Contact

---



Signature of Provider/Agency Contact

April 14, 2025

Date

---

**The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.**

Julie Hermansen

Printed Name of DSS Staff

---



3/14/2025, 1:39:50 PM

Signature of DSS Staff:

March 14, 2025

Date

---