

Date Issued May 19, 2025 Status Closed

Provider Name TIGER DEN KIDDIE CARE

Provider ID 011102549

Provider Address 420 5th Ave, Ipswich, SD 57451, USA

Provider Contact Nichol Osborne

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:39

For family day care providers, unused electrical outlets must have an outlet plug cover, have a tamper-resistant cover, or be made inaccessible to a child. For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

Summary of Non-Compliance Finding:

The outlets in the area with the pack and plays by the kitchen were not self closing, or tamper resistant.

Corrections to be Made:

All unused electrical outlets in the area with the pack and plays by the kitchen need to be self-closing or tamper resistant.

Corrections Made:

Self-closing covers were installed on the electrical outlets in the area with the pack and plays by the kitchen.

Anticipated Completion Date:

June 09, 2025

Date Completed:

June 11, 2025

Compliance Plan Action #2

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these

exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and

(5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

The fire extinguishers were last inspected in June 2023.

Corrections to be Made:

The fire extinguishers need to be inspected by a qualified service technician.

Corrections Made:

The fire extinguishers were inspected by a qualified service agent.

Anticipated Completion Date:
June 09, 2025

Date Completed:
May 22, 2025

Compliance Plan Action #3

Administrative Rule:

67:42:17:33

A provider shall meet the following requirements regarding bathrooms:

- (1) Bathroom facilities must be easily accessible by children and providers;
- (2) Hot water for faucets normally used by children in care may not exceed one hundred twenty degrees Fahrenheit;

- (3) Toilets and hand sinks must be kept clean and in good repair; and
- (4) For child care centers and school-age programs:
 - (4a) All bathrooms must have natural or mechanical ventilation;
 - (4b) Separate bathrooms must be available for males and females;
 - (4c) Ratios for toilet and hand sinks must align with the minimum standards for plumbing and plumbing systems published by the plumbing commission.

Except in a family day care, hand sinks must be in the same room, or an unobstructed room adjacent to the diaper changing area. A handwashing sink used after diapering and toileting may not be used for food preparation.

Summary of Non-Compliance Finding:

The restroom marked for men was blocked with a rocking chair and other storage. Only the one bathroom was accessible.

Corrections to be Made:

The rocking chair and storage blocking the men's bathroom entrance need to be removed. The bathroom facilities need to be easily accessible

Corrections Made:

The rocking chair and storage were removed from blocking the men's bathroom.

Anticipated Completion Date:
June 09, 2025

Date Completed:
May 21, 2025

Compliance Plan Action #4

Administrative Rule:

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

The baseboard in the dining area was laying on the floor, and not attached to the wall.

Corrections to be Made:

The baseboard in the dining area needs to be attached to the wall.

Corrections Made:

The baseboard in the dining area has been attached to the wall.

Anticipated Completion Date:

June 09, 2025

Date Completed:

June 11, 2025

Compliance Plan Action #5

Administrative Rule:

67:42:17:31

An infant shall be fed according to the infant's schedule. The provider shall hold the infant's bottle when feeding the infant. The provider may not feed an infant by propping up the infant's bottle. Food, including breast milk and formula, must be properly stored, kept at the proper temperature, and protected from potential contamination according to the preparing, feeding, and storing standards contained in Caring for Our Children: National Health and Safety Performance Standards, 4th Edition.

Summary of Non-Compliance Finding:

Bleach, and other cleaning chemicals, were stored on the top shelf of the storage racks in the kitchen. This was over food and utensil items.

Corrections to be Made:

The bleach, and other cleaning chemicals need to be moved so these chemicals are not stored over food and kitchen utensil items.

Corrections Made:

The bleach and other cleaning chemicals were moved to a cabinet with a child safety latch and not stored over food and utensils.

Anticipated Completion Date:

Date Completed:

May 26, 2025

June 11, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Nichol Osborne

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

May 19, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Julie Hermansen

Printed Name of DSS Staff



5/19/2025, 4:29:31 PM

Signature of DSS Staff:

May 19, 2025

Date