

Date Issued	May 19, 2025	Status	Closed
Provider Name	IMAGINATION STATION		
Provider ID	018039999		
Provider Address	207 S Main Ave, Hartford, SD 57033, USA		
Provider Contact	Kristine Johnson		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:39

For family day care providers, unused electrical outlets must have an outlet plug cover, have a tamper-resistant cover, or be made inaccessible to a child. For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

Summary of Non-Compliance Finding:

During inspection, an outlet did not have a tamper-resistant cover outside of the Rhino's room.

Corrections to be Made:

The provider will ensure a tamper-resistant outlet cover is installed.

Corrections Made:

The provider submitted verification to OLA of the tamper-resistant outlet on 6/12/2025.

Anticipated Completion Date:
May 23, 2025

Date Completed:
June 12, 2025

Compliance Plan Action #2

Administrative Rule:

67:42:17:33

A provider shall meet the following requirements regarding bathrooms:

- (1) Bathroom facilities must be easily accessible by children and providers;
- (2) Hot water for faucets normally used by children in care may not exceed one hundred twenty degrees Fahrenheit;

- (3) Toilets and hand sinks must be kept clean and in good repair; and
- (4) For child care centers and school-age programs:
 - (4a) All bathrooms must have natural or mechanical ventilation;
 - (4b) Separate bathrooms must be available for males and females;
 - (4c) Ratios for toilet and hand sinks must align with the minimum standards for plumbing and plumbing systems published by the plumbing commission.

Except in a family day care, hand sinks must be in the same room, or an unobstructed room adjacent to the diaper changing area. A handwashing sink used after diapering and toileting may not be used for food preparation.

Summary of Non-Compliance Finding:

During inspection, a hand sink was obstructed by a door in the diaper changing area.

Corrections to be Made:

The provider will ensure hand sinks are unobstructed to the diaper changing area.

Corrections Made:

The provider submitted verification that the door to the handwashing sink for diapering remains unobstructed from the diaper changing area.

Anticipated Completion Date:

May 23, 2025

Date Completed:

May 27, 2025

Compliance Plan Action #3

Administrative Rule:

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

At the time of inspection, two classrooms had vents that did not appear to be kept clean.

Corrections to be Made:

The provider will ensure the vents in each classroom are clean and kept in good repair.

Corrections Made:

The provider submitted verification to OLA that both vents were cleaned.

Anticipated Completion Date:

May 23, 2025

Date Completed:

June 04, 2025

Compliance Plan Action #4

Administrative Rule:

67:42:17:35

Playgrounds for all child care settings must be safe, in good repair, and free of debris, trash, and weeds. Playground equipment must be installed according to the manufacturer's instructions and maintained in good repair. For a center program, a fence that measures at least four feet high is required around the center's outdoor play space. For a family day care or school-age program, a fence that measures at least forty-two inches high may be required to separate the outdoor play space, if the department determines a body of water, vehicular traffic, or other hazard poses a risk of injury or death to a child.

Summary of Non-Compliance Finding:

During inspection, the fence in the outdoor play area was not found to be kept in good repair.

Corrections to be Made:

The provider will ensure the repair and maintenance of the outdoor fence.

Corrections Made:

The provider submitted verification of the replacement of the outdoor fence on 6/09/2025.

Anticipated Completion Date:

May 23, 2025

Date Completed:

June 09, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Kristine Johnson

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

May 09, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Morgan Jensen

Printed Name of DSS Staff



5/16/2025, 10:08:01 AM

Signature of DSS Staff:

May 09, 2025

Date