

---

Date Issued	April 15, 2025	Status	Closed
Provider Name	<u>Westside After School Program (WASP)</u>		
Provider ID	<u>011102381</u>		
Provider Address	<u>320 Walnut St W, Sisseton, SD 57262, USA</u>		
Provider Contact	<u>Alica Finnesand</u>		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

### Compliance Plan Action #1

**Administrative Rule:**

67:42:17:39

For family day care providers, unused electrical outlets must have an outlet plug cover, have a tamper-resistant cover, or be made inaccessible to a child.

For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

**Summary of Non-Compliance Finding:**

The electrical outlets in the gym do not have self-closing or tamper resistant outlet covers.

**Corrections to be Made:**

The electrical outlets must have self-closing or tamper-resistant covers.

**Corrections Made:**

Self-closing outlet covers were installed in the Gym electrical outlets.

**Anticipated Completion Date:**  
May 01, 2025

**Date Completed:**  
July 08, 2025

**Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.**

Alicia Finnesand  
Printed Name of Provider/Agency Contact



\_\_\_\_\_  
Signature of Provider/Agency Contact

\_\_\_\_\_  
April 15, 2025


\_\_\_\_\_  
Date

---

**The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.**

Julie Hermansen

\_\_\_\_\_  
Printed Name of DSS Staff



4/15/2025, 3:51:20 PM

\_\_\_\_\_  
Signature of DSS Staff:

\_\_\_\_\_  
April 15, 2025

\_\_\_\_\_  
Date