

Date Issued	May 13, 2025	Status	Closed
Provider Name	LOLA - FREEMAN DAVIS		
Provider ID	011102575		
Provider Address	601 4th St E, Mobridge, SD 57601, USA		
Provider Contact	Emily Moser		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

The toaster oven on the counter in the classroom is not under a residential hood system.

Corrections to be Made:

The toaster oven needs to be removed from the classroom to the kitchen.

Corrections Made:

The toaster oven was removed from the classroom.

Anticipated Completion Date:
May 21, 2025

Date Completed:
July 09, 2025

Compliance Plan Action #2

Administrative Rule:

67:42:17:39

For family day care providers, unused electrical outlets must have an outlet plug cover, have a tamper-resistant cover, or be made inaccessible to a child.

For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

Summary of Non-Compliance Finding:

The self-closing electrical cover on the outlet by the small fridge in the classroom was removed.

Corrections to be Made:

All unused electrical outlets need to be need to be self-closing or tamper resistant. The outlet by the small fridge needs to be changed to self-closing or tamper resistant.

Corrections Made:

The electrical outlet cover by the small fridge was changed to a self-closing electrical outlet.

Anticipated Completion Date:

May 21, 2025

Date Completed:

July 09, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Emily Moser

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact


May 13, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Julie Hermansen

Printed Name of DSS Staff



5/1/2025, 1:29:32 PM

Signature of DSS Staff:

May 01, 2025

Date
