

Date Issued	July 03, 2025	Status	Closed
Provider Name	CHILDREN'S CARE CORNER		
Provider ID	010605880		
Provider Address	206 N Main St, Howard, SD 57349, USA		
Provider Contact	Abby Anderberg-Kramer		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:33

A provider shall meet the following requirements regarding bathrooms:

- (1) Bathroom facilities must be easily accessible by children and providers;
- (2) Hot water for faucets normally used by children in care may not exceed one hundred twenty degrees Fahrenheit;
- (3) Toilets and hand sinks must be kept clean and in good repair; and
- (4) For child care centers and school-age programs:
 - (a) All bathrooms must have natural or mechanical ventilation;
 - (b) Separate bathrooms must be available for males and females;
 - (c) Ratios for toilet and hand sinks must align with the minimum standards for plumbing and plumbing systems published by the plumbing commission.

Except in a family day care, hand sinks must be in the same room, or an unobstructed room adjacent to the diaper changing area. A handwashing sink used after diapering and toileting may not be used for food preparation.

Summary of Non-Compliance Finding:

The hot water temperature was measured at 125 degrees F during the inspection.

Corrections to be Made:

The hot water temperature must be maintained at 120 degrees F or cooler; the correction must be completed by 06/25/25.

Corrections Made:

Verification was received that the issue was corrected.

Anticipated Completion Date:
July 07, 2025

Date Completed:
July 14, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Rita Little Thunder

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

June 18, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Deb Bigge

Printed Name of DSS Staff



6/18/2025, 3:09:48 PM

Signature of DSS Staff:

June 18, 2025

Date