
Date Issued	August 01, 2025	Status	Closed
Provider Name	<u>B&G CLUB 57TH ST. LEARNING CENTER</u>		
Provider ID	<u>018042257</u>		
Provider Address	<u>5015 S Crossing Pl #150, Sioux Falls, SD 57108, USA</u>		
Provider Contact	<u>Whitney Alley</u>		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

Storage in a room was observed to be within 2 feet from the ceiling.

Corrections to be Made:

In storage rooms, combustible materials need to be maintained at least 2 feet below the ceiling or 18 inches below sprinkler head deflectors.

Corrections Made:

Storage in all rooms was moved down to be within 2 feet or more from the ceiling.

Anticipated Completion Date:
August 08, 2025

Date Completed:
August 06, 2025

Compliance Plan Action #2

Administrative Rule:

67:42:17:31

An infant shall be fed according to the infant's schedule. The provider shall hold the infant's bottle when feeding the infant. The provider may not feed an infant by propping up the infant's bottle.

Food, including breast milk and formula, must be properly stored, kept at the proper temperature, and protected from potential contamination according to the preparing, feeding, and storing standards contained in **Caring for Our Children: National Health and Safety Performance Standards, 4th Edition.**

Summary of Non-Compliance Finding:

The refrigerator in a classroom measured above 41 degrees F.

Corrections to be Made:

Refrigerator temperature should be maintained at 41 degrees F or below to ensure proper storage of food.

Corrections Made:

The refrigerator temperature was turned down to measure at 41 degrees F or below.

Anticipated Completion Date:
August 08, 2025

Date Completed:
August 06, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Whitney Alley

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

August 01, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Brooke Flemmer

Printed Name of DSS Staff



7/30/2025, 11:10:16 AM

Signature of DSS Staff:

July 30, 2025

Date