

Date Issued	August 08, 2025	Status	Closed
Provider Name	<u>GO KIDS DAYCARE & LEARNING CENTER</u>		
Provider ID	<u>018042120</u>		
Provider Address	<u>6820 W 26th St, Sioux Falls, SD 57106, USA</u>		
Provider Contact	<u>Jamie Elg</u>		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:33

A provider shall meet the following requirements regarding bathrooms:

- (1) Bathroom facilities must be easily accessible by children and providers;
- (2) Hot water for faucets normally used by children in care may not exceed one hundred twenty degrees Fahrenheit;
- (3) Toilets and hand sinks must be kept clean and in good repair; and
- (4) For child care centers and school-age programs:
 - (a) All bathrooms must have natural or mechanical ventilation;
 - (b) Separate bathrooms must be available for males and females;
 - (c) Ratios for toilet and hand sinks must align with the minimum standards for plumbing and plumbing systems published by the plumbing commission.

Except in a family day care, hand sinks must be in the same room, or an unobstructed room adjacent to the diaper changing area. A handwashing sink used after diapering and toileting may not be used for food preparation.

Summary of Non-Compliance Finding:

All the boys' and girls' bathrooms had water temperatures above 120°F.
The changing pad in the Hippo classroom is torn.

Corrections to be Made:

Adjust the temperature in the bathrooms to below 120°F.
Replace the pad for changing diapers in the Hippo classroom.

Corrections Made:

The provider submitted evidence to the Office of Licensing & Accreditation confirming that the water temperatures have been adjusted and the changing pad in the Hippo Classroom has been replaced.

Anticipated Completion Date:
August 08, 2025

Date Completed:
August 01, 2025

Compliance Plan Action #2

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

The fire alarm system was in trouble mode.

Corrections to be Made:

A qualified service technician must inspect the fire alarm system.

Corrections Made:

The provider submitted documentation that a certified technician inspected the fire alarm system to ensure it is operational.

Anticipated Completion Date:

August 08, 2025

Date Completed:

August 01, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Jamie Elg

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

July 25, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Teri Pieters

Printed Name of DSS Staff



7/25/2025, 11:39:14 AM

Signature of DSS Staff:

July 25, 2025

Date