

Date Issued	September 03, 2025	Status	Closed
Provider Name	BUSY B's II		
Provider ID	014512628		
Provider Address	1215 S Courtland St, Chamberlain, SD 57325, USA		
Provider Contact	Blakely Nogy		

**The items listed below are those that the provider was not in compliance with at the time of the inspection.**

### Compliance Plan Action #1

**Administrative Rule:**

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

**Summary of Non-Compliance Finding:**

At the time of the inspection, the fire extinguishers were last inspected in March 2024.

**Corrections to be Made:**

Fire extinguishers must be inspected/serviced annually.

**Corrections Made:**

Verification that the fire extinguishers have been inspected was received.

**Anticipated Completion Date:**

**Date Completed:**

**Compliance Plan Action #2**

**Administrative Rule:**

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

**Summary of Non-Compliance Finding:**

At the time of the inspection, there was no documentation of the annual heating and cooling inspection.

**Corrections to be Made:**

Heating and cooling systems must be inspected annually by a certified technician.

**Corrections Made:**

Verification of the annual inspection has been received.

**Anticipated Completion Date:**

September 09, 2025

**Date Completed:**

September 03, 2025

**Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.**

Blakely Nogy

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

September 02, 2025

Date

**The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.**

Sarah Deakins

Printed Name of DSS Staff

---



8/25/2025, 10:14:45 AM

Signature of DSS Staff:

---

August 25, 2025

Date

---