

Date Issued	September 09, 2025	Status	Closed
Provider Name	<u>Hillsview Day Care Center</u>		
Provider ID	<u>016599178</u>		
Provider Address	<u>1200 N 10th St, Spearfish, SD 57783, USA</u>		
Provider Contact	<u>Valerie Thoreson</u>		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

An exit sign in the basement multipurpose room was not working.
Decorations were hanging from a door frame blocking exiting.
The program did not have a copy of the heating and cooling inspection available at the time of inspection.

Corrections to be Made:

The exit sign must be repaired and verification must be sent to the Office of Licensing and Accreditation.
The decorations must be removed, this was corrected immediately.
A copy of the heating and cooling inspection must be submitted to the Office of Licensing and Accreditation.

Corrections Made:

The exit sign was repaired and a picture was sent to the Office of Licensing and Accreditation to verify.
The decorations were removed at the time of inspection.
A heating and cooling inspection was conducted, and verification was sent to the Office of Licensing and Accreditation.

Anticipated Completion Date:
September 10, 2025

Date Completed:
September 09, 2025

Compliance Plan Action #2

Administrative Rule:

67:42:17:33

A provider shall meet the following requirements regarding bathrooms:

- (1) Bathroom facilities must be easily accessible by children and providers;
- (2) Hot water for faucets normally used by children in care may not exceed one hundred twenty degrees Fahrenheit;
- (3) Toilets and hand sinks must be kept clean and in good repair; and
- (4) For child care centers and school-age programs:
 - (a) All bathrooms must have natural or mechanical ventilation;
 - (b) Separate bathrooms must be available for males and females;
 - (c) Ratios for toilet and hand sinks must align with the minimum standards for plumbing and plumbing systems published by the plumbing commission.

Except in a family day care, hand sinks must be in the same room, or an unobstructed room adjacent to the diaper changing area. A handwashing sink used after diapering and toileting may not be used for food preparation.

Summary of Non-Compliance Finding:

A vent fan was not working in the boy's bathroom.

Corrections to be Made:

The vent must be repaired and verification must be submitted to the Office of Licensing and Accreditation.

Corrections Made:

The vent was replaced and verification of completion was sent to the Office of Licensing and Accreditation.

Anticipated Completion Date:

September 10, 2025


Date Completed:

September 09, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Valerie Thoresen

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

September 05, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Tina Uecker

Printed Name of DSS Staff



9/9/2025, 12:32:49 PM

Signature of DSS Staff:

September 09, 2025

Date
