
Date Issued	June 06, 2025	Status	Closed
Provider Name	<u>South Park Discovery Center</u>		
Provider ID	<u>016597768</u>		
Provider Address	<u>207 Flormann St, Rapid City, SD 57701, USA</u>		
Provider Contact	<u>Kellsie Judge</u>		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:39

For family day care providers, unused electrical outlets must have an outlet plug cover, have a tamper-resistant cover, or be made inaccessible to a child.

For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

Summary of Non-Compliance Finding:

Outlet panel strips do not have tamper-resistant or self-closing outlets.

Corrections to be Made:

Program will ensure outlets have a self-closing outlet covers or are tamper-resistant. Verification of compliance will be submitted to the Office of Licensing & Accreditation. The program has requested additional time to correct the electrical outlets.

Corrections Made:

Program replaced the outlets to meet the Child Care Licensing rule and notified the Office of Licensing and Accreditation of the correction.

Anticipated Completion Date:
December 31, 2025

Date Completed:
September 26, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Kellsie Judge
Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

May 30, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Andrea Neff

Printed Name of DSS Staff



5/13/2025, 7:59:01 AM

Signature of DSS Staff:

May 13, 2025

Date