

Date Issued September 11, 2025 Status Closed

Provider Name KID'S CROSSING DAYCARE CENTER  
Provider ID 018042391  
Provider Address 6101 S Mogen Ave Unit 5, Sioux Falls, SD 57108, USA  
Provider Contact Keisha Kenner

**The items listed below are those that the provider was not in compliance with at the time of the inspection.**

### Compliance Plan Action #1

**Administrative Rule:**

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

**Summary of Non-Compliance Finding:**

At the time of the inspection there was no documentation of the annual heating and cooling system inspection.

**Corrections to be Made:**

Documentation of the annual inspection to be provided to the Office of Licensing and Accreditation.

**Corrections Made:**

Documentation of annual inspections received on 10-02-25. See document for details.

**Anticipated Completion Date:**  
September 30, 2025

**Date Completed:**  
October 02, 2025

### Compliance Plan Action #2

**Administrative Rule:**

67:42:17:33

A provider shall meet the following requirements regarding bathrooms:

- (1) Bathroom facilities must be easily accessible by children and providers;
- (2) Hot water for faucets normally used by children in care may not exceed one hundred twenty degrees Fahrenheit;

- (3) Toilets and hand sinks must be kept clean and in good repair; and
- (4) For child care centers and school-age programs:

- (a) All bathrooms must have natural or mechanical ventilation;
- (b) Separate bathrooms must be available for males and females;
- (c) Ratios for toilet and hand sinks must align with the minimum standards for plumbing and plumbing systems published by the plumbing commission.

Except in a family day care, hand sinks must be in the same room, or an unobstructed room adjacent to the diaper changing area. A handwashing sink used after diapering and toileting may not be used for food preparation.

**Summary of Non-Compliance Finding:**

At the time of the inspection, a handwashing sink was being used to rinse bottles in the Sloth room.

**Corrections to be Made:**

Handwashing sinks are not to be used for bottle preparation.

**Corrections Made:**

Director has identified an alternate sink in the room that is to be used for bottle preparation. Staff have been advised not to use handwashing sink beginning immediately and moving forward.

**Anticipated Completion Date:**  
September 30, 2025

**Date Completed:**  
September 10, 2025

**Compliance Plan Action #3**

**Administrative Rule:**

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must

be inaccessible to children.

**Summary of Non-Compliance Finding:**

At the time of the inspection, the following compliance items were noted:

There was no documentation of the annual sprinkler system inspection.

An exit was blocked.

**Corrections to be Made:**

Documentation of annual sprinkler system inspection to be provided to the Office of Licensing and Accreditation.

Exit to be cleared and documentation to be provided to the Office of Licensing and Accreditation.

**Corrections Made:**

09-18-25 Documentation of cleared exit received.

10-07-2025 Documentation of sprinkler system inspection received on this date.

**Anticipated Completion Date:**

September 30, 2025

**Date Completed:**

October 07, 2025

**Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.**

Keisha Kenner

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

September 11, 2025

Date

**The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.**

Rita Trager

Printed Name of DSS Staff



9/11/2025, 8:31:12 AM

Signature of DSS Staff:

---

September 11, 2025

Date

---