

Date Issued	August 06, 2025	Status	Closed
Provider Name	Discovery CLC		
Provider ID	1280444298		
Provider Address	1506 S Discovery Ave, Sioux Falls, SD 57106, USA		
Provider Contact	Caitlyn Dikoff		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

Two exit signs located in the gym did not illuminate when tested.

Corrections to be Made:

The provider will send written verification to the Office of Licensing and Accreditation that the exit signs have been repaired and illuminate when testing.

Corrections Made:

OLA observed that the exit signs have been repaired and illuminate when tested.


Anticipated Completion Date:
August 22, 2025

Date Completed:
August 25, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Caitlyn Dikoff

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact


August 06, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Stacie Ugofsky

Printed Name of DSS Staff


8/6/2025, 7:42:45 AM

Signature of DSS Staff:

August 06, 2025

Date