

---

Date Issued	November 04, 2025	Status	Closed
Provider Name	PEJUTA HAKA WAKANYEJA CENTER		
Provider ID	016597790		
Provider Address	438 Main St, Kyle, SD 57752, USA		
Provider Contact	Saige Pourier		

---

**The items listed below are those that the provider was not in compliance with at the time of the inspection.**

### Compliance Plan Action #1

**Administrative Rule:**

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

**Summary of Non-Compliance Finding:**

The fire extinguishers did not have verification that they had been inspected in the last year.

**Corrections to be Made:**

Fire extinguishers must be inspected yearly. Program must send in verification to the Office of Licensing and Accreditation verifying that the extinguishers have been inspected.

**Corrections Made:**

The program submitted pictures of the fire extinguishers and verification that they had been inspected in the last year.

**Anticipated Completion Date:**  
November 07, 2025

**Date Completed:**

**Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.**

Saige Pourier

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

November 04, 2025

Date

**The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.**

Tina Uecker

Printed Name of DSS Staff



10/30/2025, 7:51:03 AM

Signature of DSS Staff:

October 30, 2025

Date