

Provider required to post this report.

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **McCook Central After School Program**

City: **Salem**

Provider Number: **014512636**

Inspector: **Sarah Boese**

Date of Inspection: **12/06/2024**

Time of Inspection: **12:53 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

16. Do all unused electrical outlets have self-closing or tamper resistant childproof electrical covers?
67:42:17:39

NOTE: Outlet plug covers are not permitted.

Corrections To Be Made:

Outlets in the main room do not have self-closing electrical covers.

All unused electrical outlets are to have self-closing or tamper resistant childproof electrical covers.

Verification of correction was received.

Agency Action:

Compliance Plan

Suggested Completion Date:	Actual Completion Date:
12/16/2024	03/26/2025
Status: Corrected	



Provider Signature

Masey Pechholt

Name

12/06/2024

Date



Inspector Signature

Sarah Boese

Name

12/06/2024

Date