

Date Issued	November 05, 2025	Status	Closed
Provider Name	Kids 'R' Kids Prairie Hills		
Provider ID	018043101		
Provider Address	2201 W Trevi Pl, Sioux Falls, SD 57108, USA		
Provider Contact	Mike Smith		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

The sprinkler riser room is being used for storage and is inaccessible without moving objects out of the way. The exit sign leading to the STEM room did not light up when tested.

Corrections to be Made:

The program will provide evidence of a clear path to access the sprinkler system for the Office of Licensing and Accreditation.

The program will provide evidence to the Office of Licensing and Accreditation that a qualified technician serviced the exit sign.

Corrections Made:

The program provided evidence of a clear path to access the sprinkler system to the Office of Licensing and Accreditation.

The program provided evidence to the Office of Licensing and Accreditation that a qualified technician has serviced the exit sign.

Anticipated Completion Date:
December 05, 2025

Date Completed:
November 12, 2025

Compliance Plan Action #2**Administrative Rule:**

67:42:17:44

All toxic or hazardous substances must be:

- (1) Inaccessible to children;
- (2) Used according to manufacturer's instructions;
- (3) Stored in the original or other labeled container; and
- (4) Disposed of according to manufacturer recommendations.

Bio-contaminants must be handled and disposed of properly.

Soiled diapers must be changed promptly, in a designated area, on a non-porous surface. The diaper changing area must be clean and disinfected with a sanitizing solution approved by the department. Soiled diapers must be kept in a leakproof, nonabsorbent container that is covered with a tight-fitting lid.

Summary of Non-Compliance Finding:

The labels at the main bleach mixing station were reversed, resulting in a mix-up between the sanitizing solution for the diaper-changing area and toys.

Corrections to be Made:

The program will fix the labels to show the correct sanitizing solutions.

Corrections Made:

The program corrected the inverted labels, allowing the inspector to verify completion before the end of the inspection.

Anticipated Completion Date:
November 03, 2025

Date Completed:
November 03, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Richelle Inman

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact


November 05, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Teri Pieters

Printed Name of DSS Staff


11/5/2025 10:21:51 AM

Signature of DSS Staff:

November 05, 2025

Date