
Date Issued	October 23, 2025	Status	Closed
Provider Name	<u>St. Joseph's School OST Program</u>		
Provider ID	<u>709436690</u>		
Provider Address	<u>210 E Broadway Ave, Pierre, SD 57501, USA</u>		
Provider Contact	<u>Samson Boutchee</u>		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

The fire alarm system was not operational at the time of inspection. Verification of an inspection of the fire alarm system completed within the past year was available.

Corrections to be Made:

The fire alarm system must be operable. The fire alarm system must be inspected/serviced annually by a qualified service technician.

Corrections Made:

Verification has been received.

Anticipated Completion Date:
October 25, 2025

Date Completed:
October 01, 2025

Compliance Plan Action #2

Administrative Rule:

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

Documentation of inspections of the heating and cooling systems completed within the last year were not available.

Corrections to be Made:

The heating and cooling systems must be inspected annually by a certified technician.

Corrections Made:

Verification has been received.

Anticipated Completion Date:
October 25, 2025

Date Completed:
October 01, 2025

Compliance Plan Action #3

Administrative Rule:

67:42:17:39

For family day care providers, unused electrical outlets must have an outlet plug cover, have a tamper-resistant cover, or be made inaccessible to a child.

For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

Summary of Non-Compliance Finding:

The outlets in the gym and ASP room did not have self-closing or tamper resistant outlet covers.

Corrections to be Made:

Self-closing or tamper resistant covers must be installed.

Corrections Made:

Verification has been received.

Anticipated Completion Date:
October 09, 2025

Date Completed:
October 22, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Samson Boutchee
Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

October 23, 2025
Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Sarah Deakins
Printed Name of DSS Staff



Signature of DSS Staff:

September 26, 2025
Date

9/26/2025, 4:15:42 PM