

Date Issued	November 06, 2025	Status	Closed
Provider Name	McCook Central After School Program		
Provider ID	289784270		
Provider Address	200 E Essex Ave, Salem, SD 57058, USA		
Provider Contact	Masey Pechholt		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

Several tiles in the girls and boys bathrooms used by the program have water damage.

Corrections to be Made:

The ceilings must be kept in good repair; the damaged tiles are to be replaced.

Corrections Made:

Verification was received that the damaged tiles were replaced.

Anticipated Completion Date:
December 05, 2025

Date Completed:
November 24, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Jessica Bridges
Printed Name of Provider/Agency Contact

Jessica Bridges

Signature of Provider/Agency Contact

November 06, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Deb Bigge

Printed Name of DSS Staff

Deb Bigge

11/6/2025, 9:20:38 AM

Signature of DSS Staff:

November 06, 2025

Date