

Date Issued	November 05, 2025	Status	Closed
Provider Name	<u>SINTE GLESKA UNIVERSITY CHILD CARE</u>		
Provider ID	<u>015508238</u>		
Provider Address	<u>900 US-18, Mission, SD 57555, USA</u>		
Provider Contact	<u>Cheryl Whirlwind Soldier</u>		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

Program did not have a carbon monoxide detector.

Corrections to be Made:

Program will need to install a carbon monoxide detector according to the manufacturer's instructions and submit proof to the Office of Licensing & Accreditation.

Corrections Made:

Program installed a carbon monoxide detector according to the manufacturer's instructions and submitted proof to the Office of Licensing & Accreditation.

Anticipated Completion Date:
November 18, 2025

Date Completed:
November 25, 2025

Compliance Plan Action #2

Administrative Rule:

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

Programs floors are dirty with dead bugs. Program has not been operational since May 2025.

Corrections to be Made:

Program will need to clean the floors and send verification to the Office of Licensing & Accreditation.

Corrections Made:

Program cleaned the floors and sent verification to the Office of Licensing & Accreditation.

Anticipated Completion Date:
November 18, 2025

Date Completed:
November 25, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Cheryl Whirlwind Soldier

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact


November 05, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Andrea Neff

Printed Name of DSS Staff

A handwritten signature in black ink, appearing to read 'ANeff', written over a horizontal line.

11/4/2025, 3:19:02 PM

Signature of DSS Staff:

November 04, 2025

Date