

shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

At the time of the inspection, the inspector was unable to locate a carbon monoxide detector. There was no documentation of an annual fire alarm inspection.

Corrections to be Made:

A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home. Programs with more than 21 children, must have the fire alarm system inspected and serviced annually by a qualified technician.

Corrections Made:

Verification of an installed carbon monoxide detector has been received. Verification of the annual fire alarm inspection has been received.


Anticipated Completion Date:
October 23, 2025

Date Completed:
November 25, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Lindsay Strohfus

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact


October 06, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Sarah Deakins

Printed Name of DSS Staff



9/24/2025, 9:42:21 AM

Signature of DSS Staff:

October 14, 2025

Date