

---

Date Issued	December 11, 2025	Status	Closed
Provider Name	<u>SNICKLEFRITZ SOUTH KIDS CLUB</u>		
Provider ID	<u>018042942</u>		
Provider Address	<u>412 N Cliff Avenue, Harrisburg, SD 57032, USA</u>		
Provider Contact	<u>Amber Vandenberg</u>		

**The items listed below are those that the provider was not in compliance with at the time of the inspection.**

### Compliance Plan Action #1

**Administrative Rule:**

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

**Summary of Non-Compliance Finding:**

The fire alarm and fire extinguisher maintenance report was unavailable during the inspection.  
A carbon monoxide detector was not located during the inspection.

**Corrections to be Made:**

The fire alarm system and fire extinguishers must be inspected and serviced annually by a qualified service technician.  
A carbon monoxide detector must be installed according to the manufacturer's instructions.

**Corrections Made:**

A copy of the current fire alarm inspection report was provided to the Office of Licensing and Accreditation. During an onsite visit, it was confirmed that the fire extinguishers have been inspected and are up to date that a carbon monoxide detector had been installed.

**Anticipated Completion Date:**  
December 11, 2025

**Date Completed:**  
March 25, 2025

## Compliance Plan Action #2

### **Administrative Rule:**

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

### **Summary of Non-Compliance Finding:**

The HVAC inspection report was not available at the time of the inspection.

### **Corrections to be Made:**

The heating and cooling system must be inspected and serviced annually by a qualified service technician.

### **Corrections Made:**

A copy of the current heating and cooling report was provided to the Office of Licensing and Accreditation.

**Anticipated Completion Date:**  
April 30, 2025

**Date Completed:**  
March 25, 2025

**Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.**

Karli Dubro

Printed Name of Provider/Agency Contact



\_\_\_\_\_  
Signature of Provider/Agency Contact

\_\_\_\_\_  
April 16, 2025

\_\_\_\_\_  
Date

---

**The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.**

\_\_\_\_\_  
Teri Pieters

\_\_\_\_\_  
Printed Name of DSS Staff



12/11/2025, 11:56:01 AM

\_\_\_\_\_  
Signature of DSS Staff:

\_\_\_\_\_  
December 11, 2025

\_\_\_\_\_  
Date