

Date Issued	November 10, 2025	Status	Closed
Provider Name	HAWTHORNE ELEMENTARY CLC		
Provider ID	018043146		
Provider Address	601 N Spring Ave, Sioux Falls, SD 57104, USA		
Provider Contact	Saundra Larson		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

Exit/Flood light in front of elevator door on third floor needs maintenance. The light does not illuminate when test button is pressed.

Corrections to be Made:

Exit/flood light to illuminate when tested. Documentation to be provided to the Office of Licensing and Accreditation.

Corrections Made:

Documentation of exit light repairs received on 12-11-2025.

Anticipated Completion Date:
November 29, 2025

Date Completed:
December 11, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Saundra Larson

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

November 10, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Rita Trager

Printed Name of DSS Staff



10/29/2025, 3:34:40 PM

Signature of DSS Staff:

October 23, 2025

Date