

Date Issued	December 11, 2025	Status	Closed
Provider Name	Wonder and Willow		
Provider ID	399691314		
Provider Address	1500 Sedivy Ln, Rapid City, SD 57703, USA		
Provider Contact	Caleb Grenz		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

There is not a current inspection of the eating and cooling system.

Corrections to be Made:

The heating and cooling system need to be inspected and verification of completion must be submitted to the Office of Licensing and Accreditation.

Corrections Made:

An inspection was completed on the heating and cooling system and copy of the inspection was provided to the Office of Accreditation.

Anticipated Completion Date:
December 11, 2025

Date Completed:
November 10, 2025

Compliance Plan Action #2

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building

shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

The program did not have a carbon monoxide detector.

The fire alarm system had not been inspected in the last year.

Two exit signs were not illuminated and operational.

Corrections to be Made:

A carbon monoxide detector must be installed and verification must be sent to the Office of Licensing and Accreditation.

The fire alarm system must be inspected and a copy of the report must be submitted to the Office of Licensing and Accreditation.

The exit signs must be repaired and in working order.

Corrections Made:

The program installed a carbon monoxide detector and verification was sent in to the Office of Licensing and Accreditation.

The exit signs were repaired and observed by the Office of Licensing and Accreditation on 11/6/25

The fire alarm system was inspected on 11/7/25 and a copy of the report was sent to the Office of Licensing and Accreditation.

Anticipated Completion Date:

December 31, 2025

Date Completed:

December 03, 2025

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Olyvia Bridges

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

November 18, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Tina Uecker

Printed Name of DSS Staff



12/11/2025, 3:27:45 PM

Signature of DSS Staff:

December 11, 2025

Date