

Date Issued	December 15, 2025	Status	Closed
Provider Name	Tiny Treasures		
Provider ID	605685327		
Provider Address	816 E Clark St, Vermillion, SD 57069, USA		
Provider Contact	Rachel Wudel		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:33

A provider shall meet the following requirements regarding bathrooms:

- (1) Bathroom facilities must be easily accessible by children and providers;
- (2) Hot water for faucets normally used by children in care may not exceed one hundred twenty degrees Fahrenheit;
- (3) Toilets and hand sinks must be kept clean and in good repair; and
- (4) For child care centers and school-age programs:
 - (a) All bathrooms must have natural or mechanical ventilation;
 - (b) Separate bathrooms must be available for males and females;
 - (c) Ratios for toilet and hand sinks must align with the minimum standards for plumbing and plumbing systems published by the plumbing commission.

Except in a family day care, hand sinks must be in the same room, or an unobstructed room adjacent to the diaper changing area. A handwashing sink used after diapering and toileting may not be used for food preparation.

Summary of Non-Compliance Finding:

At the time of the inspection, the hot water temperature in the restroom was 125 degrees.

Corrections to be Made:

Hot water temperature to be turned down to 120 degrees or less. Documentation to be provided to the Office of Licensing and Accreditation.

Corrections Made:

The hot water temperature was turned down to be 120 degrees or less.

Anticipated Completion Date:
January 09, 2026

Date Completed:
January 05, 2026

Compliance Plan Action #2

Administrative Rule:

67:42:17:39

For family day care providers, unused electrical outlets must have an outlet plug cover, have a tamper-resistant cover, or be made inaccessible to a child.

For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

Summary of Non-Compliance Finding:

At the time of the inspection there were unused outlet covers that did not have self-closing or tamper-resistant covers in place.

Corrections to be Made:

Self-closing or tamper-resistant covers to be installed at the site.

Corrections Made:

Outlets in the rooms used for care were changed to be tamper resistant.

Anticipated Completion Date:

January 09, 2026

Date Completed:

January 02, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Rachel Wudel

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

December 15, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Rita Trager

Printed Name of DSS Staff



12/11/2025, 10:31:40 AM

Signature of DSS Staff:

December 11, 2025

Date
