

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Canton Area Preschool and Child Care**

City: **Canton**

Provider Number: **018042945**

Inspector: **Sarah Boese**

Date of Inspection: **09/27/2024**

Time of Inspection: **12:33 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. Environmental Health

45. Are hazardous cleaning supplies inaccessible to children and stored in their original container, used, and disposed of in accordance with manufacturer's instructions? 67:42:17:44

Corrections To Be Made:

Bleach bottles were found unmarked in the Bathroom, Toddler (2), and Be-kindergarten rooms. The bathroom bleach bottle was within reach of the children; The bathroom with a washing machine had a bucket of powder detergent within reach of the children.

Hazardous cleaning supplies are to be inaccessible to children and stored in their original container(s), used, and disposed of in accordance with the manufacturer's instructions.

Correction: All bleach bottles are clearly labeled, and both the bleach and detergent have been relocated out of children's reach. The director will monitor and retrain staff to ensure that all items remain labeled and out of children's reach.

Agency Action:

Compliance Plan

Suggested Completion Date:	Actual Completion Date:
----------------------------------	-------------------------------

10/07/2024	10/03/2024
-------------------	-------------------

Status: **Corrected**

47. When children are in care, is the temperature maintained between 65 - 75 degrees F? 67:42:17:32

Corrections To Be Made:

Be-kindergarten room had a malfunctioning window air conditioner. The windows were open, and the room temperature was above 75 degrees F.

When children are in care, the temperature should be maintained between 65- and 75-degrees Fahrenheit.

Correction: The air conditioner has been defrosted and is maintaining the room at approximately 70 degrees F.

Agency Action:

Compliance Plan

Suggested Completion Date:	Actual Completion Date:
----------------------------------	-------------------------------

10/07/2024	10/03/2024
-------------------	-------------------

Status: **Corrected**

49. Are all walls, ceilings, floors, and equipment easily cleanable, kept clean and in good repair? 67:42:17:32

Corrections To Be Made:

Gym/Stage area has multiple water stains on the ceiling and smell of mildew.

All walls, ceilings, floors, and equipment are to be easily cleanable, kept clean and in good repair.

Correction: The ceiling tiles were replaced because of a roof leak, which caused them to smell of mildew. The program is now fixing the roof to prevent future leaks. The program is currently repairing the roof to prevent future leaks.

Agency Action:

Compliance Plan

Suggested Completion Date:	Actual Completion Date:
----------------------------------	-------------------------------

12/17/2024	12/17/2024
-------------------	-------------------

Status: **Corrected**

57. Is the outside play area safe, in good repair, and free of debris, trash, weeds and hazardous material? 67:42:17:35

Corrections To Be Made:

A tree fell and damaged the outdoor playground fence.

The outside play area is to be safe, in good repair, and free of debris, trash, weeds and hazardous material.

Correction: The program is replacing the damaged section of the fence.

Agency Action:

Compliance Plan

Suggested Completion Date:	Actual Completion Date:
12/17/2024	04/30/2025
Status:	Corrected

Miscellaneous Rule Violations

67:42:17:35 - Playground requirements

Corrections To Be Made:

Outside play area has improper hanging infant swing and buckets of water were discovered in an area of heavy foliage.

The outside play area is to be safe, in good repair, and free of debris, trash, weeds and hazardous material.

Correction: The program properly rehung the infant swing, removed the buckets, and trimmed back the dense foliage.

Agency Action:

Compliance Plan

Suggested Completion Date:	Actual Completion Date:
10/07/2024	10/07/2024
Status:	Corrected



Provider Signature

Melissa Klein

Name

09/27/2024

Date



Inspector Signature

Sarah Boese

Name

09/27/2024

Date