

Date Issued	February 16, 2026	Status	Closed
Provider Name	<u>LITTLE ANGELS</u>		
Provider ID	<u>011515893</u>		
Provider Address	<u>711 W Kemp Ave, Watertown, SD 57201, USA</u>		
Provider Contact	<u>Angela LaFramboise</u>		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

At time of inspection, fire alarm panel was in trouble mode, fire extinguishers hadn't been inspected since September 2024, and items are being stored more than 2 feet from the ceiling.

Corrections to be Made:

Licensed child care facilities must follow applicable construction and fire safety requirements, as outlined in ARSD chapters 61:15:05 and 61:15:06.

Corrections Made:

Pictures received as verification that all issues have been resolved. Fire extinguisher inspected, items removed from top


cabinet, and fire alarm panel fixed.

Anticipated Completion Date:
February 16, 2026

Date Completed:
February 17, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Angela LaFramboise
Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

February 16, 2026
Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Ambuer Jaacks
Printed Name of DSS Staff



2/3/2026, 4:12:22 PM
Signature of DSS Staff:

February 03, 2026
Date