

Date Issued	February 24, 2026	Status	Closed
Provider Name	SDSU Early Learning Center		
Provider ID	011517222		
Provider Address	401 1st Ave, Brookings, SD 57006, USA		
Provider Contact	Barb Caulfield		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

At time of inspection, verification of when heating and cooling system was last inspected not available.

Corrections to be Made:

For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician

Corrections Made:

Verification provided that HVAC system has been inspected in the past year by a certified technician.

Anticipated Completion Date:
March 09, 2026

Date Completed:
February 24, 2026

Compliance Plan Action #2

Administrative Rule:

67:42:17:39

For family day care providers, unused electrical outlets must have an outlet plug cover, have a tamper-resistant cover, or be made inaccessible to a child.

For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

Summary of Non-Compliance Finding:

At time of inspection, a shelving unit in a classroom had a power strip that did not have tamper resistant outlet cover.

Corrections to be Made:

For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

Corrections Made:

Verification received that the shelf has been moved to be out of reach of children. Outlets on the shelving unit will not be used.

Anticipated Completion Date:
March 09, 2026

Date Completed:
February 24, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Barb Caulfield

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

February 24, 2026

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Ambuer Jaacks

Printed Name of DSS Staff



2/23/2026, 4:41:00 PM

Signature of DSS Staff:

February 23, 2026

Date