

Date Issued	December 18, 2025	Status	Closed
Provider Name	Pulse of Life Kids Care		
Provider ID	018043136		
Provider Address	1330 E Main St, Vermillion, SD 57069, USA		
Provider Contact	Angela Jackson		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

During a review of the facility's basement construction, it was determined that the basement stairs are not properly enclosed.

Corrections to be Made:

The walls and soffits within enclosed usable spaces under enclosed and unenclosed stairways must be protected with 1-hour fire-resistance-rated construction, or the fire-resistance rating of the stairway enclosure, whichever is greater. Sheetrock will be installed to fully enclose the exposed area.

Corrections Made:

The basement is now enclosed and the city of Vermillion issued a full certificate of occupancy for their lower-level.


Anticipated Completion Date:
March 01, 2026

Date Completed:
March 01, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Angela Jackson

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

December 17, 2025

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Rita Trager

Printed Name of DSS Staff



12/16/2025, 1:54:00 PM

Signature of DSS Staff:

December 16, 2025

Date