

---

Date Issued	March 18, 2026	Status	Closed
Provider Name	<u>IMAGINATION STATION</u>		
Provider ID	<u>018039999</u>		
Provider Address	<u>207 S Main Ave, Hartford, SD 57033, USA</u>		
Provider Contact	<u>Kristine Johnson</u>		

**The items listed below are those that the provider was not in compliance with at the time of the inspection.**

### Compliance Plan Action #1

**Administrative Rule:**

67:42:17:39

For family day care providers, unused electrical outlets must have an outlet plug cover, have a tamper-resistant cover, or be made inaccessible to a child.

For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

**Summary of Non-Compliance Finding:**

During the inspection, one electrical outlet in the “jumping” room was observed to be neither self-closing nor equipped with a tamper-resistant cover.

**Corrections to be Made:**

The provider will ensure that all electrical outlets are equipped with either self-closing covers or tamper-resistant covers.

**Corrections Made:**

Verification of compliance was received.

**Anticipated Completion Date:**  
March 25, 2026

**Date Completed:**  
March 19, 2026

**Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.**

Kristine Johnson  
Printed Name of Provider/Agency Contact



\_\_\_\_\_  
Signature of Provider/Agency Contact

\_\_\_\_\_  
March 05, 2026

Date

---

**The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.**

\_\_\_\_\_  
Morgan Giraldo

Printed Name of DSS Staff



3/4/2026, 3:46:21 PM

\_\_\_\_\_  
Signature of DSS Staff:

\_\_\_\_\_  
March 04, 2026

Date