

Date Issued	March 24, 2026	Status	Closed
Provider Name	IMPACT KIDZ ACADEMY		
Provider ID	1126922301		
Provider Address	625 N Creek Dr, Rapid City, SD 57703, USA		
Provider Contact	Nancy Pruitt		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

Several emergency exit doors from the classrooms were blocked by tables.

Corrections to be Made:

Exit pathways must be maintained to ensure a minimum unobstructed width of 36 inches for access to hallways and exit doors.

Corrections Made:

The program has maintained a minimum clearance of 36 inches to the emergency exit doors and has submitted verification of compliance to the Office of Licensing and Accreditation.

Anticipated Completion Date:
March 24, 2026

Date Completed:
March 06, 2026

Compliance Plan Action #2

Administrative Rule:

67:42:17:44

All toxic or hazardous substances must be:

- (1) Inaccessible to children;
- (2) Used according to manufacturer's instructions;
- (3) Stored in the original or other labeled container; and
- (4) Disposed of according to manufacturer recommendations.

Bio-contaminants must be handled and disposed of properly.

Soiled diapers must be changed promptly, in a designated area, on a non-porous surface. The diaper changing area must be clean and disinfected with a sanitizing solution approved by the department. Soiled diapers must be kept in a leakproof, nonabsorbent container that is covered with a tight-fitting lid.

Summary of Non-Compliance Finding:

There are tears in the diaper changing mats in classrooms T6, T7 and T9.

Corrections to be Made:

Program will need to replace diaper changing mats in classrooms T6, T7 and T9.

Corrections Made:

Program replaced the diaper changing mats in classrooms T6, T7 and T9 and submitted verification to the Office of Licensing & Accreditation.

Anticipated Completion Date:
March 24, 2026

Date Completed:
March 06, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Kelly Wood

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

March 06, 2026

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Andrea Neff

Printed Name of DSS Staff



3/5/2026, 1:16:59 PM

Signature of DSS Staff:

March 05, 2026

Date
