

| | | | |
|------------------|---------------------------------------|--------|--------|
| Date Issued | February 19, 2026 | Status | Closed |
| Provider Name | YMCA YOUTH DEVELOPMENT CENTER | | |
| Provider ID | 011008567 | | |
| Provider Address | 6 S State St, Aberdeen, SD 57401, USA | | |
| Provider Contact | Kaitlyn Fair | | |

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

Combustible material was stored within 18" of the ceiling in the storage near the infant rooms on the east side of the building.

Corrections to be Made:

Move combustible materials to 2" feet below the ceiling or 18" below sprinkler heads in the storage near the infant rooms on the east side of the building.

Corrections Made:

The combustible materials were moved 18" below the sprinkler heads in the infant rooms storage on the east side of the

building.

Anticipated Completion Date:
March 17, 2026

Date Completed:
March 10, 2026

Compliance Plan Action #2

Administrative Rule:

67:42:17:35

Playgrounds for all child care settings must be safe, in good repair, and free of debris, trash, and weeds. Playground equipment must be installed according to the manufacturer’s instructions and maintained in good repair.

For a center program, a fence that measures at least four feet high is required around the center’s outdoor play space.

For a family day care or school-age program, a fence that measures at least forty-two inches high may be required to separate the outdoor play space, if the department determines a body of water, vehicular traffic, or other hazard poses a risk of injury or death to a child.

Summary of Non-Compliance Finding:

The gray climbing wall equipment on the west side has broken ropes.

Corrections to be Made:

Repair or remove broken ropes on the gray climbing wall equipment. The broken ropes have been removed from the climbing structure. The play structure will not be used until it is repaired.

Corrections Made:

The broken ropes on the gray climbing structure were replaced and the structure is safe and functional.

Anticipated Completion Date:
March 17, 2026

Date Completed:
April 06, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Tevan Head

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

February 19, 2026

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Julie Hermansen

Printed Name of DSS Staff



2/18/2026, 10:13:15 AM

Signature of DSS Staff:

February 18, 2026

Date
