COMPLIANCE PLAN
OFFICE OF LICENSING & ACCREDITATION

South Dakota Department of Social Services

Date Issued	April 14, 2026	Status	In Process

Provider Name	Glory House of Sioux Falls
Provider ID	ACC1027
Provider Address	4000 S West Ave, Sioux Falls, SD 57105
Provider Contact	Nicole Dvorak

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:61:10:02

Each building an agency owns, rents, or leases, to provide residential services must comply with applicable fire safety standards, as set forth in the 2012 edition of the NFPA 101 Life Safety Code. An automatic sprinkler system is not required in an existing facility unless significant renovation or remodeling occurs. An existing automatic sprinkler system must remain in service.

New construction, renovations, additions, and changes of space must comply with NFPA 101 Life Safety Code, 2012 edition. Each facility must comply with the building construction standards of the International Building Code, 2012 edition.

Summary of Non-Compliance Finding:

The ceilings in the basement electrical room of the Sands Freedom Center had water damage. There is a moldlike substance growing on the ceiling.

Corrections to be Made:

A private contractor will be making the necessary repairs and removing the mold like substance.

Corrections Made:

Anticipated Completion Date:
May 20, 2026

Date Completed:

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Nicole Dvorak

Printed Name of Provider/Agency Contact

	April 14, 2026
Signature of Provider/Agency Contact	Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Printed Name of DSS Staff

Signature of DSS Staff:	Date