

Date Issued April 20, 2026 Status Closed

Provider Name DOLAND COMMUNITY DAYCARE

Provider ID 011102464

Provider Address 202 3rd St, Doland, SD 57436, USA

Provider Contact Melinda Rowe

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:44

All toxic or hazardous substances must be:

- (1) Inaccessible to children;
- (2) Used according to manufacturer's instructions;
- (3) Stored in the original or other labeled container; and
- (4) Disposed of according to manufacturer recommendations.

Bio-contaminants must be handled and disposed of properly.

Soiled diapers must be changed promptly, in a designated area, on a non-porous surface. The diaper changing area must be clean and disinfected with a sanitizing solution approved by the department. Soiled diapers must be kept in a leakproof, nonabsorbent container that is covered with a tight-fitting lid.

Summary of Non-Compliance Finding:

Provider

is using Lysol Disinfectant wipes to sanitize the changing table. Disinfectant wipe are not approved as a sanitizer.

Corrections to be Made:

The Provider will use an approved sanitizer for the diaper changing surface.

Corrections Made:

Bleach water will be used to sanitize the diaper changing surface.

Anticipated Completion Date:
April 20, 2026

Date Completed:
April 16, 2026

Compliance Plan Action #2

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

Food pantry storage has combustible material less than 24" from ceiling.

Corrections to be Made:

The storage in the food pantry needs to be less than 24" from the ceiling.

Corrections Made:

Storage in the food pantry was moved 24" from the ceiling.

Anticipated Completion Date:
April 08, 2026

Date Completed:
April 17, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Melinda Jean Rowe
Printed Name of Provider/Agency Contact



March 16, 2026

Signature of Provider/Agency Contact

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Julie Hermansen

Printed Name of DSS Staff



3/12/2026, 5:09:51 PM

Signature of DSS Staff:

March 12, 2026

Date