
Date Issued	April 22, 2026	Status	Closed
Provider Name	<u>SNICKLEFRITZ SOUTH</u>		
Provider ID	<u>018042235</u>		
Provider Address	<u>414 N Cliff Avenue, Harrisburg, SD 57032, USA</u>		
Provider Contact	<u>Amber Vandenberg</u>		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

The program's utility closet contained an excess of stored items, preventing the required three feet of clearance around the electrical panel and HVAC units.

At the time of the inspection, a carbon monoxide detector could not be located.

Corrections to be Made:

The program will organize the utility closet to ensure the required three feet of clearance is maintained around the electrical panel and HVAC units and will upload a photo to the Office of Licensing and Accreditation.

The program will locate or install a carbon monoxide detector and provide a photo to the Office of Licensing and Accreditation.

Corrections Made:

The program organized the utility closet to ensure the required three feet of clearance is maintained around the electrical panel and HVAC units and uploaded a photo to the Office of Licensing and Accreditation.

The program provided the Office of Licensing and Accreditation with documentation of the installed carbon monoxide

detector.

Anticipated Completion Date:
May 15, 2026

Date Completed:
April 24, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Karli Dubro
Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

April 22, 2026
Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Teri Pieters
Printed Name of DSS Staff



Signature of DSS Staff:

April 17, 2026
Date

4/17/2026, 1:39:53 PM