

Date Issued	May 11, 2026	Status	Closed
Provider Name	CHILDREN'S HOUSE MONTESSORI		
Provider ID	016597783		
Provider Address	4021 Range Rd, Rapid City, SD 57702, USA		
Provider Contact	Michelle Kagamanov		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:33

A provider shall meet the following requirements regarding bathrooms:

- (1) Bathroom facilities must be easily accessible by children and providers;
- (2) Hot water for faucets normally used by children in care may not exceed one hundred twenty degrees Fahrenheit;
- (3) Toilets and hand sinks must be kept clean and in good repair; and
- (4) For child care centers and school-age programs:
 - (a) All bathrooms must have natural or mechanical ventilation;
 - (b) Separate bathrooms must be available for males and females;
 - (c) Ratios for toilet and hand sinks must align with the minimum standards for plumbing and plumbing systems published by the plumbing commission.

Except in a family day care, hand sinks must be in the same room, or an unobstructed room adjacent to the diaper changing area. A handwashing sink used after diapering and toileting may not be used for food preparation.

Summary of Non-Compliance Finding:

Exhaust fan in bathroom is not working.

Corrections to be Made:

Program will repair exhaust fan in bathroom and submit verification to the Office of Licensing & Accreditation.

Corrections Made:

Compliance issue was not corrected as the program is relocating to another building.

Anticipated Completion Date:
May 12, 2026

Date Completed:
May 13, 2026

Compliance Plan Action #2

Administrative Rule:

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

Gas furnace was not inspected.

Corrections to be Made:

Program will have the gas furnace inspected by a certified technician and submit verification to the Office of Licensing & Accreditation.

Corrections Made:

Compliance issue was not corrected as the program is relocating to another building.

Anticipated Completion Date:

May 12, 2026

Date Completed:

May 13, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Michelle Kagarmanov

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

May 11, 2026

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Andrea Neff

Printed Name of DSS Staff

A handwritten signature in black ink, appearing to be 'A. L. H.' or similar, written in a cursive style.

4/28/2026, 3:30:59 PM

Signature of DSS Staff:

April 28, 2026

Date