

Date Issued	May 01, 2026	Status	Closed
Provider Name	SCARBROUGH CENTER		
Provider ID	018030125		
Provider Address	2304 N Lackey Pl, Sioux Falls, SD 57107, USA		
Provider Contact	Robin Sjogren		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

Multiple exit signs in facility failed back-up power testing as they were either too dim or did not illuminate during testing. Additionally, the exit corridor heading to the east exit has toys and a storage bin along the wall causing a narrowing of the hallway below 36".

Corrections to be Made:

Exit signs must be interior or exterior illuminated or self-luminous. Exit aisle widths need to be maintained at 36 inches or more.

Corrections Made:

All exit signs in facility illuminate when tested. The pathway for the exit corridor was cleared so that the exit aisle widths was at least 36".

Anticipated Completion Date:

May 29, 2026

Date Completed:

May 06, 2026

Compliance Plan Action #2**Administrative Rule:**

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

At the time of the inspection the program did not have documentation of the annual inspections of the fuel-fired equipment.

Corrections to be Made:

All heating and cooling systems must be inspected annually, by a certified technician.

Corrections Made:

Documentation of the heating and cooling systems inspected was sent to the Office of Licensing and Accreditation.

Anticipated Completion Date:

May 29, 2026

Date Completed:

May 12, 2026

Compliance Plan Action #3**Administrative Rule:**

67:42:17:35

Playgrounds for all child care settings must be safe, in good repair, and free of debris, trash, and weeds. Playground equipment must be installed according to the manufacturer's instructions and maintained in good repair.

For a center program, a fence that measures at least four feet high is required around the center's outdoor play space.

For a family day care or school-age program, a fence that measures at least forty-two inches high may be required to separate the outdoor play space, if the department determines a body of water, vehicular traffic, or other hazard poses a risk of injury or death to a child.

Summary of Non-Compliance Finding:

The chain link fence on the east perimeter of the playground is missing a series of clips for the fence connecting vertical poles. Those clips are on the bottom part of the fence causing the fence to bend outward when pushed.

Corrections to be Made:

Playgrounds for all child care settings must be safe, in good repair, and free of debris, trash, and weeds.

Corrections Made:

The chain link fence was repaired to have all clips for the fence connecting the vertical poles.

Anticipated Completion Date:

May 29, 2026

Date Completed:

May 19, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Robin Sjogren

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

May 01, 2026

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Brooke Flemmer

Printed Name of DSS Staff



Signature of DSS Staff:

April 29, 2026

Date

4/29/2026, 1:09:44 PM