

Date Issued	May 27, 2026	Status	Closed
Provider Name	INSPIRE LEARNING CENTER		
Provider ID	018043198		
Provider Address	910 N Main Ave Suite 105, Tea, SD 57064, USA		
Provider Contact	Jana Schenk		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

The electrical panel was obstructed and not readily accessible.

Corrections to be Made:

The program will clear items blocking the electrical panel and provide photographs to the Office of Licensing and Accreditation

Corrections Made:

The program cleared items blocking the electrical panel and provided photographs to the Office of Licensing and Accreditation

Anticipated Completion Date:
May 29, 2026

Date Completed:
May 27, 2026

Compliance Plan Action #2

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building

shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

The inspector was unable to ensure backup exit sign batteries were installed and functioning properly.

A carbon monoxide detector was not installed in the HVAC/furnace room containing fuel-burning equipment.

A fire extinguisher was sitting on the ground.

Corrections to be Made:

The program will ensure backup exit sign batteries are installed and functioning properly, and provide documentation to the Office of Licensing and Accreditation.

The program will install a carbon monoxide detector in the HVAC and furnace room and will provide documentation to the Office of Licensing and Accreditation.

The program will provide the Office of Licensing and Accreditation with documentation regarding the placement of the fire extinguisher.

Corrections Made:

The program installed backup batteries for exit signs and provided documentation to the Office of Licensing and Accreditation.

The program installed a carbon monoxide detector in the HVAC and furnace room and provided documentation to the Office of Licensing and Accreditation.

The program provided the Office of Licensing and Accreditation with documentation regarding the placement of the fire extinguisher.

Anticipated Completion Date:

May 29, 2026

Date Completed:

May 27, 2026

Compliance Plan Action #3

Administrative Rule:

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling

systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

The refrigerator was not clean at the time of the visit.

Corrections to be Made:

The program will send photos of the cleaned refrigerator to the Office of Licensing and Accreditation.

Corrections Made:

The program sent photos of the cleaned refrigerator to the Office of Licensing and Accreditation.

Anticipated Completion Date:

May 29, 2026

Date Completed:

May 27, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Jana Schenk

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact


May 15, 2026

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Teri Pieters

Printed Name of DSS Staff



5/27/2026, 11:25:57 AM

Signature of DSS Staff:

May 27, 2026

Date