

|                  |                                              |        |        |
|------------------|----------------------------------------------|--------|--------|
| Date Issued      | June 01, 2026                                | Status | Closed |
| Provider Name    | Uniquely Yours- Garfield Elementary          |        |        |
| Provider ID      | 485896659                                    |        |        |
| Provider Address | 705 S Roberts Dr, Sioux Falls, SD 57104, USA |        |        |
| Provider Contact | Sarah Parmenter                              |        |        |

**The items listed below are those that the provider was not in compliance with at the time of the inspection.**

#### **Compliance Plan Action #1**

**Administrative Rule:**

67:42:17:39

For family day care providers, unused electrical outlets must have an outlet plug cover, have a tamper-resistant cover, or be made inaccessible to a child.

For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

**Summary of Non-Compliance Finding:**

No outlets in the facility marked for use by Uniquely Yours are tamper-resistant.

**Corrections to be Made:**

The program will install tamper-resistant outlet covers on all electrical outlets to ensure child safety and compliance.

**Corrections Made:**

During a visit on May 26, 2026, the Licensing Specialist observed that tamper-resistant outlet covers had been installed.

**Anticipated Completion Date:**

June 01, 2026

**Date Completed:**

May 26, 2026

#### **Compliance Plan Action #2**

**Administrative Rule:**

67:42:17:35

Playgrounds for all child care settings must be safe, in good repair, and free of debris, trash, and weeds. Playground equipment must be installed according to the manufacturer's instructions and maintained in good repair.

For a center program, a fence that measures at least four feet high is required around the center's outdoor play space.

For a family day care or school-age program, a fence that measures at least forty-two inches high may be required to separate the outdoor play space, if the department determines a body of water, vehicular traffic, or other hazard poses

a risk of injury or death to a child.

**Summary of Non-Compliance Finding:**

The yellow house on the play equipment is missing bolts. One of missing bolts allows a white "step" to spin.

**Corrections to be Made:**

The program will replace or tighten loose bolts on the playground equipment to ensure the equipment is safe and properly maintained.

**Corrections Made:**

The program replaced and tightened loose bolts on the playground equipment and provided pictures to the Office of Licensing and Accreditation.

**Anticipated Completion Date:**  
June 01, 2026

**Date Completed:**  
May 27, 2026

**Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.**

Sarah Parmenter

Printed Name of Provider/Agency Contact




Signature of Provider/Agency Contact

May 28, 2026  
Date

**The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.**

Teri Pieters

Printed Name of DSS Staff



Signature of DSS Staff:

May 27, 2026  
Date